

A2O Biological Pool Calculator

Calculated value		Set value	
Back calibration	Known condition	Design criteria	

1. A2O Biological Pool Calculation

Design parameter		Water intake			
序号	item	symbol	Formula	Calculated value	unit
	Engineering design scale	Q_0		7000	m ³ /d
	Coefficient of total change	K_1		1.47	
	Average daily, average hourly flow	Q_0	$Q_0/24$	291.666667	m ³ /h
		Q_0	$Q_0/3600$	0.081018519	m ³ /s
	Maximum daily and hourly flow	Q_{max}	$Q_0 \times K_1$	428.75	m ³ /h
		Q_{max}	$Q_{max}/3600$	0.119097222	m ³ /s

Inlet and outlet water quality

Water quality parameter	Water intake index (mg/L)	symbol	Effluent index (mg/L)	symbol	Removal rate%	remark
$CO_{D,0}$	400	$CO_{D,e}$	80	$CO_{D,e}$	87.5	
$CO_{D,1}$	120	S_e	10	S_e	91.66666667	90% 95%
TSS	220	T_{ss}	10	T_{ss}	95.45454545	
NH_4-N	25	N_e	5	N_e	80	
TN	35	N_e	5	N_e	85.71428571	
NO_3-N	0	N_e	15	N_e	57.14285714	60% 65%
TP	3	P_e	0.5	P_e	83.33333333	
PH	6.9		6.3			
硬度	280	S_{H2O}				
T_{max}	20	T_c				
T_{min}	14	T_c				

water treatment

A2O Biological Reaction Tank (anaerobic/anaerobic/aerobic)

Determine whether the A2O process can be used

序号	project	symbol	Formula	Calculated value	unit	remark
	BOD5/TN (carbon-nitrogen ratio)	k_1	S_N/N_e	3.428571429		>4
	BOD5/TP (carbon-phosphorus ratio)	k_2	S_P/P_e	40		>17

A2O biological reaction tank volume calculation (sludge loading method)

parameter	value	unit	remark
A2O biological reaction tank design flow	Q_0	7000	m ³ /d
BOD5 sludge load	N	0.03	kgBOD ₅ /(kgMLSS · d)
Mixed liquid suspension solid concentration MLSS	X	3500	mgMLSS/L
Sludge reflux ratio	R	100%	reflux
Denitrification rate	η_{DN}	0.571428571	60% 65%
Mixture reflux ratio	R_{mix}	1.333333333	100% 100%
	R	2	200%

Effective volume of A2O biological reaction tank

parameter	value	unit	remark
Effective volume of A2O biological reaction tank	$V = \frac{Q(S_0 - S_e)}{NX}$	2750	m ³
	value	2750	m ³

Total residence time of A2O biological reaction tank

parameter	value	unit	remark
Total residence time of A2O biological reaction tank	$HRT = \frac{V}{Q}$	0.392857143	d
	$24 \times HRT$	9.428571429	h

The ratio of anaerobic/anoxic/aerobic residence time

parameter	value	unit	remark
Anaerobic zone residence time	$HRT_1 = \frac{V}{Q} \times \frac{1}{1+2+8} = 0.057142857$	h	
Anoxic zone residence time	$HRT_2 = \frac{V}{Q} \times \frac{2}{1+2+8} = 0.114285714$	h	
Aerobic zone residence time	$HRT_3 = \frac{V}{Q} \times \frac{8}{1+2+8} = 0.857142857$	h	
Anaerobic zone effective volume	$V_{a1} = V \times \frac{1}{1+2+8} = 250$	m ³	
Effective volume of anoxic zone	$V_{a2} = V \times \frac{2}{1+2+8} = 500$	m ³	
Aerobic zone effective volume	$V_{a3} = V \times \frac{8}{1+2+8} = 2000$	m ³	

Check nitrogen and phosphorus load

parameter	value	unit	remark
Total nitrogen load in aerobic section	$k_3 = \frac{QN}{XV_{a3}}$	0.035	kgTN/(kgMLSS · d) <0.05, Meet the requirements
Total phosphorus load in anaerobic section	$k_4 = \frac{QP}{XV_{a1}}$	0.024	kgTP/(kgMLSS · d) <0.06, Meet the requirements

Calculation of residual sludge volume

parameter	value	unit	remark
Total sludge yield (increase) coefficient	Y_e	0.6	kgMLSS/kgBOD ₅
The proportion of MLVSS in MLSS	f	0.7	kgMLVSS/kgMLSS
Endogenous metabolic coefficient (sludge oxidation rate)	K_d	0.05	d ⁻¹
Biological sludge production	$F_e = Y_e(Q(S_0 - S_e) - K_d X V)$	135135	kg/d
Production of non-biological sludge	$F_n = Q(TN - T_e) \times 50\%/1000$	125.125	kg/d
Surplus sludge production	$F_e + F_n$	860.125	kg/d

Alkalinity check

parameter	value	unit	remark
Nitrogen content in biological sludge	k_5	0.124	
Daily nitrogen removal by microbial assimilation (synthesis)	N_e	15.5193	kg/d
	$N_e \times 1000/Q$	2.2188	mg/L
The amount of NH ₃ -N that has been oxidized	N_{ox}	17.7835	mgNH ₃ -N/L
Amount of denitrification required	N_d	17.7835	mgNH ₃ -N/L
The amount of nitrate nitrogen that needs to be removed	N_r	124.4045	kgNO ₃ -N/d
The oxidation of 1mgNH ₃ -N consumes alkalinity	S_{Ca1}	7.14	mg/mgNH ₃ -N
Oxidizing NH ₃ -N consumes total alkalinity	S_{Ca2}	198.37419	mg/L
Removal of 1mgBOD ₅ produces alkalinity	S_{Ca3}	0.1	mg/mgBOD ₅
Remove the total alkalinity produced by BOD ₅	$S_{Ca4} = S_{Ca3} \times (S_0 - S_e)$	11	mg/L
Reduction of 1mgNO ₃ -N produces alkalinity	S_{Ca5}	3.57	mg/mgNO ₃ -N
Reduction of NO ₃ -N produces total alkalinity	$S_{Ca6} = S_{Ca5} \times N_r$	63.487095	mg/L
Residual alkalinity	$S_{Ca7} = S_{Ca2} - S_{Ca4} + S_{Ca6}$	156.112905	mg/L

Size calculation of A2O biological reaction cell

parameter	value	unit	group
Number of reaction pools	n	2	group
Single reaction pool capacity	V_{a1}	1375	m ³
Effective water depth of a single reaction tank	H	5	m
Effective area of a single reaction	S_{a1}	275	m ²
The number of corridors of a single push	n_1	2	pcs
Gallery width	B	9	m
Width of single reaction cell	W	18	m
Length of a single reaction pool	L	15.27777778	m
	value	15.3	m

Check the width to depth ratio

parameter	value	unit	remark
Check the width to depth ratio	$k_6 = \frac{B}{H}$	1.8	1~2
Check the aspect ratio	$k_7 = \frac{L}{B}$	0.944444444	5~10
Reaction tank super-elevation	H_1	5.5	m
Total reaction tank height	H_2	5.5	m

Calculation of inlet and outlet pipes in reaction tank

parameter	value	unit	remark
Design flow of the main inlet pipe of the reaction tank	Q_0	0.081018519	m ³ /s
Inlet pipe velocity	v_1	0.6	m/s
Cross-sectional area of water inlet pipe	S_1	0.101273148	m ²
Inlet pipe diameter	$D_1 = \sqrt{\frac{4S_1}{\pi}}$	0.359089097	m
	value	0.6	m
Check pipe flow rate	$v_1 = \frac{Q_0}{S_1} = \frac{Q_0}{\frac{\pi}{4} D_1^2}$	0.286544398	m/s
Design flow of return sludge pipe	$Q_2 = R \times Q_0$	0.081018519	m ³ /s
Flow rate of return sludge pipe	v_2	0.6	m/s
Cross-sectional area of return sludge pipe	S_2	0.101273148	m ²
Diameter of return sludge pipe	$D_2 = \sqrt{\frac{4S_2}{\pi}}$	0.359089097	m
	value	0.6	m

Design flow of inlet hole of a single biological reaction tank

parameter	value	unit	remark
Design flow of inlet hole of a single biological reaction tank	$Q_3 = (1+R) Q_0/n$	0.081018519	m ³ /s
Inlet velocity	v_3	0.6	m/s
Water inlet cross-section area	$A_3 = Q_3/v_3$	0.135030864	m ²
Long side of water inlet hole	$L_{A3} = \sqrt{A_3}$	0.36746546	m
	value	0.3	m
Weir discharge	$Q_4 = (1+R+R_0) Q_0/n$	0.162037037	m ³ /s
Outlet weir width	$B_4 = \frac{Q_4}{v_4}$	9	m
The water head above the weir	H_4	0.032	m
Flow coefficient	$m = 0.405 + \frac{0.0027}{H}$	0.43753012	
Weir discharge	$Q_4 = m B_4 \sqrt{2gH_4^{3/2}}$	0.41707783	m ³ /s
Discharge rate of water outlet	$Q_5 = \frac{Q_4}{n}$	0.162037037	m ³ /s
Outlet flow rate	v_5	0.6	m/s
Water outlet area	$A_5 = Q_5/v_5$	0.270061728	m ²
Outlet hole side length	$L_{A5} = \sqrt{A_5}$	0.519674637	m
	value	0.5	m

Design flow of outlet pipe

parameter	value	unit	remark
Design flow of outlet pipe	$Q_6 = \frac{Q_5}{n}$	0.162037037	m ³ /s
Flow rate of outlet pipe	v_6	0.6	m/s
Cross-sectional area of outlet pipe	$S_6 = Q_6/v_6$	0.202546296	m ²
Outlet pipe diameter	$D_6 = \sqrt{\frac{4S_6}{\pi}}$	0.507823867	m
	value	0.5	m
Check pipe flow rate	$v_6 = \frac{Q_6}{S_6} = \frac{Q_6}{\frac{\pi}{4} D_6^2}$	0.322362448	m/s
	value	0.6	m/s

Aeration system design and calculation

parameter	value	unit	remark	
BOD ₅ decomposition rate constant	k	0.21	d ⁻¹	
BOD ₅ test time	t	5	d	
Remove BOD ₅ oxygen demand	$D_{0(1-e^{-kt})}$	1126.779969	kgO ₂ /d	
BOD oxygen equivalent in residual sludge	D_{0e}	1.42 × P _N	177.6775	kgO ₂ /d
Carbon oxygen demand	D_{0c}	$D_{0(1-e^{-kt})} - D_{0e}$	949.102493	kgO ₂ /d
Removing NH ₃ -N oxygen demand	D_{0n}	$4.6Q_0(N_0 - N_e)/1000$	966	kgO ₂ /d
Residual sludge NH ₃ -N oxygen equivalent	D_{0n}	$4.6 \times 12.48 \times P_N$	71.3713	kgO ₂ /d
Nitrifying oxygen demand	D_{0n}	$D_{0n} - D_{0n}$	894.6287	kgO ₂ /d
Nitrogen removal by denitrification produces oxygen	D_{0n}	$2.86 \times N_e$	356.02567	kgO ₂ /d
Actual total average oxygen demand in aerobic ponds	$AOR = D_{0c} + D_{0n} - D_{0n}$	1487.705499	kgO ₂ /d	
	$AOR/24$	61.9872914	kgO ₂ /h	
Actual total maximum oxygen demand of aerobic pool	$AOR_{max} = 1.4 \times AOR$	2082.787699	kgO ₂ /d	
	$AOR_{max}/24$	86.78232079	kgO ₂ /h	
Remove 1kgBOD ₅ oxygen demand	$AOR_{BOD5} = \frac{1000 \times AOR}{Q(S_0 - S_e)}$	1.920285064	kgO ₂ /kgBOD	

Water dissolved oxygen saturation at 20°C

parameter	value	unit	remark
Water dissolved oxygen saturation at 20°C	$C_{1,20}$	9.17	mg/L
20°C water dissolved oxygen saturation	$C_{1,20}$	10.17	mg/L
Standard atmosphere	p_a	101300	Pa
Pressure correction factor	β	1	Local pressure is higher than standard pressure
Concentration of dissolved oxygen in aerobic tank	C_1	2	mg/L
Ratio of oxygen transfer rate between sewage and clean water	α	0.82	
Ratio of saturated dissolved oxygen in sewage to clean water	β	0.95	

Microporous aerator from the bottom of the pool

parameter	value	unit	remark
Microporous aerator from the bottom of the pool	H_0	0.2	m
Installation depth of microporous aerator	H_0	4.9	m
Pressure at the outlet of microporous aerator	$p_0 = p_a + 9800 \times H_0$	148340	Pa
Oxygen transfer efficiency of microporous aerator	E_a	0.2	
The percentage of oxygen when the air leaves the pool	$O_2 = \frac{2(1-E_a)}{79+2(1-E_a)}$	0.178365344	

Aerobic tank dissolved oxygen saturation

parameter	value	unit	remark
Aerobic tank dissolved oxygen saturation	$C_{1,aer} = C_{1,20} \left(\frac{p_0}{79+2(1-E_a)} + O_2 \right) = \frac{AOR \times C_{1,20}}{Q(S_0 - S_e)}$	11.54846563	mg/L
Aerobic tank standard state total average oxygen demand	$SOR = \frac{AOR}{\alpha(\beta C_{1,aer} - C_1) \times 1.024^{T-20}}$	2138.106259	kgO ₂ /d
	$SOR/24$	89.0877608	kgO ₂ /h
Aerobic pool standard state total maximum oxygen demand	$SOR_{max} = 1.4 \times SOR$	124.7228651	kgO ₂ /h
Average hourly capacity of aerobic tank	$G_1 = SOR/0.28$	1484.796013	m ³ /h
	$G_1/60$	24.74666022	m ³ /min
Average hourly capacity of a single aerobic tank	$G_{1a} = G_1/n$	742.3980066	m ³ /min
	$G_{1a}/60$	12.37330011	m ³ /min
Aerobic tank maximum hourly gas supply	$G_{max} = 1.4 \times G_1$	2078.714419	m ³ /h
	$G_{max}/60$	34.64524031	m ³ /min